

**May 2017**

**Well PW41-01251**

# **Rocky Pointe Marina - The Water We Drink 2016**

---

## **Is my water safe?**

We are pleased to present to you this year's Annual Quality Water Report for the Rocky Pointe Marina Community Water System. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

## **Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## **Where does my water come from?**

Our water source is an Artesian Deep Well. Power failures are the cause of minor shut downs .

## **Source water assessment and its availability**

Rocky Pointe Marina routinely monitors for constituents in your drinking water according to Federal and State laws. As water travels over the land or underground it can pick up substances or contaminants such as microbes, inorganic chemicals and radioactive substances. All drinking water may be reasonably expected to contain at least small amounts of some constituents. It is important to remember that the presence of the constituents does not necessarily pose a health risk.

### **Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

### **How can I get involved?**

If you have any questions about this report or concerning your water utility, please contact the Marina Office. We want our tenants to be informed about our water utility.

---

## Water Quality Data Table

The table below lists all of the drinking water test results done in 2016. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Sample ID

hemical Results - PWS ID: <a href="#">01251</a> ---- ROCKY POINTE MARINA							
Sample ID	Sample Date	Receive Date	Chemical	Source ID	Results	Current MCL	UO M
<a href="#">62790710</a> <a href="#">1-S</a>	10/05/2016	11/04/2016	ATRAZINE	EP-A	ND	0.003000	MG/L
<a href="#">62790710</a> <a href="#">1-S</a>	10/05/2016	11/04/2016	BENZO(A)PYRENE	EP-A	ND	0.000200	MG/L
<a href="#">62790710</a> <a href="#">1-S</a>	10/05/2016	11/04/2016	DI(2-ETHYLHEXYL) ADIPATE	EP-A	ND	0.400000	MG/L
<a href="#">62790710</a> <a href="#">1-S</a>	10/05/2016	11/04/2016	DI(2-ETHYLHEXYL) PHTHALATE	EP-A	ND	0.006000	MG/L
<a href="#">62790710</a> <a href="#">1-S</a>	10/05/2016	11/04/2016	HEXACHLOROBENZENE	EP-A	ND	0.001000	MG/L
<a href="#">62790710</a> <a href="#">1-S</a>	10/05/2016	11/04/2016	HEXACHLOROCYCLOPENTADIENE	EP-A	ND	0.050000	MG/L
<a href="#">62790710</a> <a href="#">1-S</a>	10/05/2016	11/04/2016	LASSO	EP-A	ND	0.002000	MG/L
<a href="#">62790710</a> <a href="#">1-S</a>	10/05/2016	11/04/2016	SIMAZINE	EP-A	ND	0.004000	MG/L
<a href="#">62590410</a> <a href="#">1-D</a>	09/15/2016	09/30/2016	TOTAL HALOACETIC ACIDS (HAA5)	DIST-A	0.001100	0.060000	MG/L
<a href="#">62590410</a> <a href="#">1-D</a>	09/15/2016	09/30/2016	TTHM	DIST-A	0.006400	0.080000	MG/L
<a href="#">62511070</a> <a href="#">1-S</a>	09/07/2016	10/07/2016	CARBOFURAN	EP-A	ND	0.040000	MG/L
<a href="#">62511070</a> <a href="#">1-S</a>	09/07/2016	10/07/2016	OXAMYL	EP-A	ND	0.200000	MG/L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2016	10/10/2016	1,2-DIBROMO-3-CHLOROPROPANE	EP-A	ND	0.000200	MG/L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2016	10/10/2016	2,4,5-TP	EP-A	ND	0.050000	MG/L

<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	2,4-D	EP-A	ND	0.07000 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	BHC-GAMMA	EP-A	ND	0.00020 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	CHLORDANE	EP-A	ND	0.00200 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	DALAPON	EP-A	ND	0.20000 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	DINOSEB	EP-A	ND	0.00700 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	DIQUAT	EP-A	ND	0.02000 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	ENDOTHALL	EP-A	ND	0.10000 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	ENDRIN	EP-A	ND	0.00200 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	ETHYLENE DIBROMIDE	EP-A	ND	0.00005 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	GLYPHOSATE	EP-A	ND	0.70000 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	HEPTACHLOR	EP-A	ND	0.00040 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	HEPTACHLOR EPOXIDE	EP-A	ND	0.00020 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	METHOXYCHLOR	EP-A	ND	0.04000 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	PENTACHLOROPHENOL	EP-A	ND	0.00100 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	PICLORAM	EP-A	ND	0.50000 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	EP-A	ND	0.00050 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-S</a>	08/31/2 016	10/10/2 016	TOXAPHENE	EP-A	ND	0.00300 MG/ 00 L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	1,1,1-TRICHLOROETHANE	EP-A	ND	0.20000 MG/ 00 L
<a href="#">62440330</a>	08/31/2	09/19/2	1,1,2-TRICHLOROETHANE	EP-A	ND	0.00500 MG/

<a href="#">1-V</a>	016	016					00 L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	1,1-DICHLOROETHYLENE	EP-A	ND	0.00700 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	1,2,4- TRICHLOROBENZENE	EP-A	ND	0.07000 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	1,2-DICHLOROETHANE	EP-A	ND	0.00500 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	1,2-DICHLOROPROPANE	EP-A	ND	0.00500 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	BENZENE	EP-A	ND	0.00500 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	CARBON TETRACHLORIDE	EP-A	ND	0.00500 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	CHLOROBENZENE	EP-A	ND	0.10000 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	CIS-1,2- DICHLOROETHYLENE	EP-A	ND	0.07000 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	DICHLOROMETHANE	EP-A	ND	0.00500 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	ETHYLBENZENE	EP-A	ND	0.70000 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	O-DICHLOROBENZENE	EP-A	ND	0.60000 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	P-DICHLOROBENZENE	EP-A	ND	0.07500 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	STYRENE	EP-A	ND	0.10000 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	TETRACHLOROETHYLEN E	EP-A	ND	0.00500 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	TOLUENE	EP-A	ND	1.00000 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	TRANS-1,2- DICHLOROETHYLENE	EP-A	ND	0.10000 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	TRICHLOROETHYLENE	EP-A	ND	0.00500 00	MG/ L
<a href="#">62440330</a> <a href="#">1-V</a>	08/31/2 016	09/19/2 016	VINYL CHLORIDE	EP-A	ND	0.00200 00	MG/ L
<a href="#">62440330</a>	08/31/2	09/19/2	XYLENES, TOTAL	EP-A	ND	10.0000	MG/

<a href="#">1-V</a>	016	016					00 L
<a href="#">62370480</a>	08/24/2	08/26/2	NITRATE	EP-A	ND	10.0000 MG/	
<a href="#">1-I</a>	016	016					00 L

More current results can be seen at [www.mywater.com](http://www.mywater.com) well # PW41-01251