

May 2018

Well PW41-01251

# Rocky Pointe Marina - The Water We Drink 2017

---

## **Is my water safe?**

We are pleased to present to you this year's Annual Quality Water Report for the Rocky Pointe Marina Community Water System. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

## **Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## **Where does my water come from?**

Our water source is an Artesian Deep Well. Power failures are the cause of minor shutdowns.

## **Source water assessment and its availability**

Rocky Pointe Marina routinely monitors for constituents in your drinking water according to Federal and State laws. As water travels over the land or underground it can pick up substances or contaminants such as microbes, inorganic chemicals and radioactive substances. All drinking water may be reasonably expected to contain at least small amounts of some constituents. It is important to remember that the presence of the constituents does not necessarily pose a health risk.

### **Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

### **How can I get involved?**

If you have any questions about this report or concerning your water utility, please contact the Marina Office. We want our tenants to be informed about our water utility.

## Water Quality Data Table

The table below lists all of the drinking water test results done in 2017. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

727101701-I	09/28/2017	10/05/2017	NITRATE	EP-A	ND	10.000000	MG/L	
724912201	08/30/2017	09/22/2017	COPPER	DIST-A	0.0760000	1.3000000	MG/L	
724912201	08/30/2017	09/22/2017	LEAD	DIST-A	0.0030000	0.0150000	MG/L	
724912202	08/30/2017	09/22/2017	COPPER	DIST-A	ND	1.3000000	MG/L	
724912202	08/30/2017	09/22/2017	LEAD	DIST-A	0.0150000	0.0150000	MG/L	
724912203	08/30/2017	09/22/2017	COPPER	DIST-A	ND	1.3000000	MG/L	
724912203	08/30/2017	09/22/2017	LEAD	DIST-A	0.0040000	0.0150000	MG/L	
724912204	08/30/2017	09/22/2017	COPPER	DIST-A	ND	1.3000000	MG/L	
724912204	08/30/2017	09/22/2017	LEAD	DIST-A	0.0030000	0.0150000	MG/L	
724912205	08/30/2017	09/22/2017	COPPER	DIST-A	0.1030000	1.3000000	MG/L	
724912205	08/30/2017	09/22/2017	LEAD	DIST-A	0.0030000	0.0150000	MG/L	
Dec 06, 2017	1	R T	Tota l	Absent--7340069-01	PUBLIC RESTROOM	DIST-A	0.2 0	Dec 18, 2017
Nov 01, 2017	1	R T	Tota l	Absent--7305112-01	PUBLIC RESTROOM	DIST-A	0.8 0	Nov 09, 2017
Oct 11, 2017	1	R T	Tota l	Absent--7284059-01	PUBLIC RESTROOM	DIST-A	0.3 0	Oct 23, 2017
Sep 28, 2017	1	A S	Tota l	Absent--7271015-01	WELL	SRC-AA		Oct 03, 2017
Sep 20, 2017	1	R T	Tota l	Absent--7263106-01	PUBLIC RESTROOM	DIST-A	0.5 0	Sep 22, 2017
Aug 02, 2017	1	R T	Tota l	Absent--7214069-01	PUBLIC RESTROOM	DIST-A	0.4 0	Aug 11, 2017
Jul 05, 2017	1	R T	Tota l	Absent--7186077-01	PUBLIC RESTROOM	DIST-A	1.2 0	Jul 10, 2017
Jun 14, 2017	1	R T	Tota l	Absent--7165057-01	PUBLIC RESTROOM	DIST-A	0.2 0	Jun 23, 2017

May 03, 2017	1	R T	Tota l	Absent--7123089-01	PUBLIC RESTROOM SINK	DIST-A	1.1 0	May 05, 2017
Apr 05, 2017	1	R T	Tota l	Absent--7095079-01	PUBLIC RESTROOM SINK	DIST-A	0.2 0	Apr 10, 2017
Mar 15, 2017	1	R T	Tota l	Absent--7074053-01	PUBLIC RESTROOM	DIST-A	0.3 0	Mar 17, 2017
Feb 08, 2017	1	R T	Tota l	Absent--7039062-01	PUBLIC RESTROOM	DIST-A	0.2 0	Feb 10, 2017
Jan 04, 2017	1	R T	Tota l	Absent--7004077-01	PUBLIC REST ROOM SIN	DIST-A		Jan 16, 2017