# Rocky Pointe Marina - The Water We Drink 2021

## Is my water safe?

We are pleased to present to you this year's Annual Quality Water Report for the Rocky Pointe Marina Community Water System. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

#### Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

#### Where does my water come from?

Our water source is an Artesian Deep Well. Power failures are the cause of minor shut downs .

#### Source water assessment and its availability

Rocky Pointe Marina routinely monitors for constituents in your drinking water according to Federal and State laws. As water travels over the land or underground it can pick up substances or contaminants such as microbes, inorganic chemicals and radioactive substances. All drinking water may be reasonably expected to contain at least small amounts of some constituents. It is important to remember that the presence of the constituents does not necessarily pose a health risk.

## Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

#### How can I get involved?

If you have any questions about this report or concerning your water utility, please contact the Marina Office. We want our tenants to be informed about our water utility.

# **Water Quality Data Table**

below lists all of the drinking water test results done in 2021. The presence of contaminants in the water does not necessarily included health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The sus to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change

#### S ID: 01251 ---- ROCKY POINTE MARINA

Sample ID	Sample Date	Receive Date	Chemical	Source ID	Results	Current MCL	UOM
112301801-I	05/03/202 1	05/10/202 1	NITRATE	EP-A	ND	10.000000	MG/ L
<u>112301802-</u> <u>V</u>	05/03/202 1	05/10/202 1	DICHLOROMETHANE	EP-A	ND	0.0050000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	1,1,1-TRICHLOROETHANE	EP-A	ND	0.2000000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	1,1,2-TRICHLOROETHANE	EP-A	ND	0.0050000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	1,1-DICHLOROETHYLENE	EP-A	ND	0.0070000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	1,2,4-TRICHLOROBENZENE	EP-A	ND	0.0700000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	1,2-DICHLOROETHANE	EP-A	ND	0.0050000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	1,2-DICHLOROPROPANE	EP-A	ND	0.0050000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	BENZENE	EP-A	ND	0.0050000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	CARBON TETRACHLORIDE	EP-A	ND	0.0050000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	CHLOROBENZENE	EP-A	ND	0.1000000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	CIS-1,2- DICHLOROETHYLENE	EP-A	ND	0.0700000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	DICHLOROMETHANE	EP-A	ND	0.0050000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	ETHYLBENZENE	EP-A	ND	0.7000000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	O-DICHLOROBENZENE	EP-A	ND	0.6000000	MG/ L

# April 2022

# WELL PW41-01251

020505401	10/21/202	11/02/202					NAC/
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	P-DICHLOROBENZENE	EP-A	ND	0.0750000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	STYRENE	EP-A	ND	0.1000000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	TETRACHLOROETHYLENE	EP-A	ND	0.0050000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	TOLUENE	EP-A	ND	1.0000000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	TRANS-1,2- DICHLOROETHYLENE	EP-A	ND	0.1000000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	TRICHLOROETHYLENE	EP-A	ND	0.0050000	MG/ L
<u>029505401-</u> <u>V</u>	10/21/202 0	11/03/202 0	VINYL CHLORIDE	EP-A	ND	0.0020000	MG/ L
029505401- <u>V</u>	10/21/202 0	11/03/202 0	XYLENES, TOTAL	EP-A	ND	10.000000	MG/ L
026705801	09/22/202 0	10/05/202 0	COPPER	DIST-A	ND	1.3000000	MG/ L
026705801	09/22/202 0	10/05/202 0	LEAD	DIST-A	0.003000 0	0.0150000	MG/ L
026705802	09/22/202 0	10/05/202 0	COPPER	DIST-A	ND	1.3000000	MG/ L
026705802	09/22/202 0	10/05/202 0	LEAD	DIST-A	0.003000 0	0.0150000	MG/ L
026705803	09/22/202 0	10/05/202 0	COPPER	DIST-A	0.089000 0	1.3000000	MG/ L
026705803	09/22/202 0	10/05/202 0	LEAD	DIST-A	ND	0.0150000	MG/ L
026705804	09/22/202 0	10/05/202 0	COPPER	DIST-A	ND	1.3000000	MG/ L
026705804	09/22/202 0	10/05/202 0	LEAD	DIST-A	ND	0.0150000	MG/ L
026705805	09/22/202 0	10/05/202 0	COPPER	DIST-A	ND	1.3000000	MG/ L
026705805	09/22/202 0	10/05/202 0	LEAD	DIST-A	0.004000 0	0.0150000	MG/ L
<u>002204501-I</u>	01/22/202 0	01/30/202 0	NITRATE	EP-A	ND	10.000000	MG

April 2022 WELL PW41-01251